

Product Technical Statement



Company;	Protector Aluminium	
Product Name;	UltiM8 Pool Fencing with G8 Safe/ SafeTech Hardware	
Type and/ or use of product;	Certified for use as a Swimming Pool Barriers	
Description of product;	Aluminium Pool Fencing, Gates and Gate Hardware	
Performance Requirements;	AS1926.1-2007/2012	Section 3 Loading Requirements
BCA (2019);	Volume One (Amdt. 1) - N/A	Volume Two – 3.10.1(a), (b)

Limitations and Conditions		
1	With regards to strength and/or rigidity of Safety Barriers for Swimming Pools, this Supplier Statement limits compliance with AS1926.1 to the following extent;	
	AS1926.1 – 2012:	Compliance with the test for Strength and Rigidity of Barrier Openings and the Strength Test for Rigid Barrier Components Only.
	AS1926.1 – 2007:	Compliance with the test for Strength and Rigidity of Barrier Openings and the Strength Test for Rigid Barrier Components Only.
	AS1926.1 – 1993:	Compliance with the test for Strength and Rigidity of Barrier Openings and the Strength Test for Rigid Barrier Components Only.
	AS1170.1 – 2002	Safety Barriers for Swimming Pools do not fulfil the performance requirements for balustrade purposes and are not suitable to be used where the fall exceeds one meter.
2	Where used as a Safety Barrier of Fencing for Swimming Pools; compliance of the barrier with Section 3.2 (Strength of Posts and Footings) of AS1926.1- 2007 and AS1926.1-1993 and Section 3.5 of AS1926.1-2012 (Strength and Rigidity of a Gate Unit) is to be confirmed to the satisfaction of the Appropriate Authority. <i>Note: UltiM8 Pool Barriers are not designed to withstand the strength, rigidity and loading requirements for balustrade use</i>	
3	When incorporating a G8 Safe (Branded) Top Pull Latch Models; Tri Latch, Pool Safe Latch, Simple Safe Latch this meets and exceeds all requirements Durability, Strength and Rigidity, Closing and Latching and Security of Closure requirements for Gate Units of Australian Standard AS 1926.1- 2007/ 2012.	
4	For the purposes of this Supplier Statement, the term Appropriate Authority has the meaning defined in the National Construction Code.	
5	For Swimming Pool Barriers, the Product Technical Statement only applies to the Product Statement holders Ulti-M8 swimming pool panels as appropriately stamped by the Product Statement holder.	
6	Information contained herein or related hereto is intended only for evaluation by technically skilled persons, with any use thereof to be at their independent discretion and risk. Nothing in this document should be construed as a warranty or guarantee by PCME Certifications, and the only applicable warranties will be those provided by the Product Technical Statement Holder.	

Issue Date: 24th November 2020

Expiry Date: 23rd November 2021

Product Technical Statement Number: 100101

Product Technical Statement



7 This Product Technical Statement is issued based on the evidence of compliance as detailed herein. Any deviation from the specifications contained in this Product Technical Statement is outside of this documents scope and the installation of the certified product/ system will not be covered by this PCME Supplier Statement. This may result in product being classified as a non-conforming building product/ system.


Product Technical Data

Building Classification/s;	1a & 10
Type and intended use of a product;	As per Page 1 (Protector Aluminium Supplier Technical Statement)
Description of product;	Aluminium pool fencing and Gate Hardware
Product specification;	Fence Panel (Up to) 3000mm x 1200mm Custom Manufactured Pool Fence Panel (Up to) 3000mm x 1200mm (2350mm – 3000mm wide panels must have a Centre Foot) (1200mm – 1800mm high panels must have a centre rail located at 1200mm height) Gates 975mm x 1200mm Custom manufactured gates (up to 1200mm wide x 1800mm high must have a centre rail located at 1200mm height). <i>Note: Pool fence panels are not suitable for use where falls exceed one meter</i>

UltiM8 Pool Fencing Flat Top Spacing's (Panels and Gates), Post's and Panel Brackets;

Flat Top Spacings for Panels and Gates;

- Powder Coated Aluminium- Aluminium grade/ temper – 6063/T6
- 6-point welds
- 24 pickets (per 2350mm width panel)
- 98.6mm centres
- 82.6mm picket spaces
- Pickets – 16mm (internally ribbed tube)
- Rails – 38mm x 25mm (internally ribbed tube)



Issue Date: 24th November 2020

Expiry Date: 23rd November 2021


Product Technical Statement Number: 100101

Product Technical Statement




UltiM8 Pool Panel Loop Top Spacings;

- Powder Coated Aluminium- Aluminium grade/ temper – 6063/T6
- 6-point welds
- 24 pickets (per 2450mm width panel)
- 98.6mm centres
- 82.6mm picket spaces
- Pickets – 16mm (internally ribbed tube)
- Rails – 38mm x 25mm (internally ribbed tube)



Ulti-M8 Pool Panel DTR Spacing's;

- Powder Coated Aluminium- Aluminium grade/ temper – 6063/T6
- 6-point welds
- 24 pickets (per 2450mm width panel)
- 91.3mm centres
- 75.3mm picket spaces
- Pickets – 16mm (internally ribbed tube)
- Rails – 38mm x 25mm (internally ribbed tube)



Accessories for Pool Fencing;

Posts;

- 50x50x1800mm
- 50x50x1300mm (Flanged)
- 50x50x2100mm (Gate Latch Post)
- 50x50x1600mm (Gate Latch Post Flanged)

Panel Brackets;

38x25mm



In-Ground Post
1800mm, 2400mm



Flanged Posts
1300mm, 1600mm



Panel Brackets

Issue Date: 24th November 2020

Expiry Date: 23rd November 2021

Product Technical Statement Number: 100101

Product Technical Statement



G8 Safe Gate Latches



G8 Safe Pool Safe Latch
SafeTech- SL-50K



G8 Safe Simple Safe Latch
SafeTech- SL-50H



G8 Safe Tri Latch
SafeTech- SL-50-Tri



G8 Safe Mega Value Kit
Consisting of;
SL50H- Gate Latch
SHG-90- Pool Compliant
Hinges

G8 Safe Pool Compliant Hinges



G8 Safe Fixed Tension
Pool Gate Hinges
SafeTech- SHF-90L



G8 Safe Fixed Tension
Pool Gate Hinges with
Legs
SafeTech- SHF-90L1



Safeklik Pool Gate
Hinges
SafeTech- SHG-90



Safeklik Pool Gate
Hinges with Legs
SafeTech- SHG-90L

Installation requirements;

Installations of these products are outside the scope of this Supplier Technical Statement. Each State in Australia has its own regulations in regard to pool fencing and must be installed in accordance to AS1926.2-2012. It is recommended that this product be installed by a suitably qualified tradesperson. The finished Pool fence must be inspected and approved by a certified pool inspector or building authority.

1. General information on the installation of this product can be found at:
https://www.protectoraluminium.com.au/pdf/HowtoinstallFencing105x297mm_AUS.pdf
2. How to Install around bends
<https://www.protectoraluminium.com.au/images/downloads/AroundtheBend.pdf>
3. Josh and Jenna "How to Install Video"
<https://youtu.be/R5vJcvSWO4k>
4. Engineering Design of Fixings for Protector Aluminium Flanged Posts, Slimline Mini Posts, Chisel Posts into Timber J190286-1a & J190286-2
5. How to Install G8 Safe "Pool Gate Latch"
<https://www.g8safe.com.au/wp-content/uploads/g8safeLatchgenericinstallA4.pdf>
6. How to Install G8 Safe Adjustable hinges
<https://www.g8safe.com.au/wp-content/uploads/g8safeHingegenericInstallA4.pdf>
7. How to Install G8 Safe Fixed Tension Hinges
<https://www.g8safe.com.au/wp-content/uploads/g8safe-Hinge-Fixed-tension-Install-A4.pdf>
8. How to Install SafeTech Hardware Pool Gate Latch
<https://www.safetechhardware.com/files/manuals/Magnetic-Pool-Gate-Latches.pdf>
9. How to Install SafeTech Hardware Adjustable Hinges
<https://www.safetechhardware.com/files/manuals/Revolutionary-Adjustable-Tension-Gate-Hinges.pdf>

Issue Date: 24th November 2020

Expiry Date: 23rd November 2021

Product Technical Statement Number: 100101

Product Technical Statement



Other relevant technical data;	State of Territory Variations; 1. In New South Wales delete 3.10.1.0(a) and insert NSW 3.10.1.0(a) as follows: (a)Performance Requirement P2.7.1 is satisfied for a swimming pool with a depth of water more than 300 mm and which is associated with a Class 1 building, if it has safety barriers installed in accordance with: (i)AS 1926 Parts 1 and 2; or (ii)If the swimming pool is a spa pool: (A)The requirements of (a)(i); or (B)Clause 9 of the Swimming Pools Regulation 2018. Application: NSW Part 3.10.1.0(a) applies in New South Wales to the technical construction requirements for barriers to restrict access to swimming pools, subject to out-of-ground pool walls and the walls of above ground pools, including inflatable pools, not being considered to be effective barriers. Note: The Swimming Pools Act 1992 and the Swimming Pools Regulation 2018, applicable to swimming pools with a depth of water of more than 300 mm, regulate the circumstances in which a barrier is required and prevail in the case of any inconsistency. 2. Part 3.10.1.0(a) does not apply in Queensland. Note: Restriction of access to swimming pools in Queensland is regulated under the Building Act 1975. 3. Part 3.10.1.0(a) does not apply in the Northern Territory. Note: Restriction of access to swimming pools in the Northern Territory is regulated under the Swimming Pool Safety Act.
---------------------------------------	---

Evaluation Statements	
Evaluation methods;	PCME Certifications has followed the following procedures for compiling of the UltiM8 Pool Fencing and Gate Hardware Supplier Statement; <ul style="list-style-type: none">- Assessment of the Protector Aluminium UltiM8 Pool Fencing and Gates products- Assessing a quality plan for Protector Aluminium that conforms to ISO1005; and- Reviewing testing of samples supplied to ascertain whether the product meets the performance requirements specified on this Technical Statement; and- Conducting site audits of the factory to verify compliance of the Safetech Hardware Pool Fencing and Gates
Note; <i>The Product Technical Statement Holder has chosen not to make the above evidence of compliance publicly available, due to the documents being considered commercial confidence. For validation of the mentioned test reports Building Authority must contact the Technical Statement Holder directly.</i>	

Issue Date:24th November 2020

Expiry Date: 23rd November 2021

Product Technical Statement Number: 100101

Product Technical Statement



Reports;

- a) Ian Bennie & Associates; NATA Accreditation No. 2371; Report #2016-053-S3; Product – Flat Top Pool Fencing. Testing to AS 1926.1:2012; Dated August 2016
Result: PASS
- b) Ian Bennies & Associates; NATA Accreditation No. 2371; Report #2016-053-S8-S10; Product – Flat Top Pool Fencing. Testing to AS 1926.1:2012; Dated August 2016
Result: PASS
- c) Ian Bennies & Associates; NATA Accreditation No. 2371; Report #2018-031-S3L: Product – Safetech Hardware Magnetic Top-Pull Pool Gate Latch- Keyless (MTPL-K). Testing to Durability, Strength and Rigidity, Closing and Latching and Security of Closure of Gate Units Tests to AS1926.1:2012; Dated May 2018
Result: PASS
- d) Ian Bennies & Associates; NATA Accreditation No. 2371; Report #2018-031-S1L: Product – Safetech Hardware Magnetic Top-Pull Pool Gate Latch (MTPL). Testing to Durability, Strength and Rigidity, Closing and Latching and Security of Closure of Gate Units Tests to AS1926.1:2012; Dated May 2018
Result: PASS
- e) Ian Bennies & Associates; NATA Accreditation No. 2371; Report #2018-031-S2L: Product – Safetech Hardware Tri Latch (TTPL). Testing to Durability, Strength and Rigidity, Closing and Latching and Security of Closure of Gate Units Tests to AS1926.1:2012; Dated May 2018
Result: PASS
- f) Ian Bennies & Associates; NATA Accreditation No. 2371; Report #2017-025-S3H: Product – Safetech Hardware Fixed Tension Hinge (SFTH-L and SHF-90L1). Testing to Durability, Strength and Rigidity, Closing and Latching and Security of Closure of Gate Units Tests to AS1926.1:2012; Dated May 2018
Result: PASS
- g) Ian Bennies & Associates; NATA Accreditation No. 2371; Report #2017-025-S3H: Product – Safetech Hardware Fixed Tension Hinge (SHG-90). Testing to Durability, Strength and Rigidity, Closing and Latching and Security of Closure of Gate Units Tests to AS1926.1:2012; Dated March 2018
Result: PASS
- h) Ian Bennies & Associates; NATA Accreditation No. 2371; Report #2017-025-S1H: Product – Safetech Hardware Adjustable Tension Hinge (SATH-L). Testing to Durability, Strength and Rigidity, Closing and Latching and Security of Closure of Gate Units Tests to AS1926.1:2012; Dated May 2018
Result: PASS

Issue Date: 24th November 2020

Expiry Date: 23rd November 2021

Product Technical Statement Number: 100101

Product Technical Statement



Scope of Supplier Technical Statement:

The PCME (Product Compliance Made Easy) Product Technical Statement is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed have been met. The responsibility for the product performance and its fitness for the intended use remain with the Supplier Technical Statement Holder. PCME Certification ensures all requirements to be classed as "Product Technical Statement", as per the National Construction Code for demonstrating compliance are fulfilled.

Disclaimer:

The Scheme Owner, Scheme Administrator do not make any representations, warranties or guarantees, and accepts no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; the Scheme Owner, Scheme Administrator disclaim to the extent permitted by law, all liability (including negligence) for any claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Supplier Technical Statement.

Note: This Product Technical Statement is only valid when reproduced in its entirety.

Stefan Ossenberg

A handwritten signature in blue ink, appearing to read 'Stefan Ossenberg', is positioned above the printed name.

PCME Certifications Representative Name

Signature

Certification Company Name: PCME Certifications

ABN: 15 818 404 064

Address: PO Box 4721 Sunshine Coast MC 4560 Qld Australia

Phone: +61422 220 192

Email: Stefan@PCMEcertifications.com

Website: www.PCMEcertifications.com

Issue Date: 24th November 2020

Expiry Date: 23rd November 2021

Product Technical Statement Number: 100101